



Polar diagram



Cone diagram



UGR diagram

| Glare evaluation according to UGR | | | | | | | | | | | |
|--|------|--|------|------|------|------|---|------|------|------|------|
| ρ Ceiling | | 70 | 70 | 50 | 50 | 30 | 70 | 70 | 50 | 50 | 30 |
| ρ Walls | | 50 | 30 | 50 | 30 | 30 | 50 | 30 | 50 | 30 | 30 |
| ρ Floor | | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 |
| Room size X Y | | Viewing direction at right angles to lamp axis | | | | | Viewing direction parallel to lamp axis | | | | |
| 2H | 2H | 17.9 | 19.0 | 18.2 | 19.2 | 19.4 | 19.7 | 20.8 | 20.0 | 21.0 | 21.2 |
| | 3H | 18.6 | 19.5 | 18.9 | 19.8 | 20.0 | 20.4 | 21.4 | 20.7 | 21.6 | 21.9 |
| | 4H | 18.9 | 19.8 | 19.2 | 20.1 | 20.4 | 20.8 | 21.7 | 21.2 | 22.0 | 22.3 |
| | 6H | 19.2 | 20.0 | 19.6 | 20.3 | 20.6 | 21.2 | 22.1 | 21.6 | 22.4 | 22.7 |
| | 8H | 19.3 | 20.1 | 19.7 | 20.4 | 20.7 | 21.4 | 22.2 | 21.7 | 22.5 | 22.8 |
| 4H | 12H | 19.4 | 20.1 | 19.7 | 20.4 | 20.8 | 21.5 | 22.3 | 21.9 | 22.6 | 23.0 |
| | 2H | 18.3 | 19.2 | 18.6 | 19.4 | 19.7 | 19.9 | 20.8 | 20.2 | 21.0 | 21.3 |
| | 3H | 19.1 | 19.9 | 19.5 | 20.2 | 20.5 | 20.7 | 21.5 | 21.1 | 21.8 | 22.1 |
| | 4H | 19.6 | 20.3 | 20.0 | 20.6 | 21.0 | 21.3 | 22.0 | 21.7 | 22.3 | 22.7 |
| | 6H | 20.0 | 20.6 | 20.4 | 21.0 | 21.4 | 21.9 | 22.4 | 22.3 | 22.8 | 23.2 |
| 8H | 8H | 20.2 | 20.7 | 20.6 | 21.1 | 21.5 | 22.1 | 22.6 | 22.5 | 23.0 | 23.4 |
| | 12H | 20.3 | 20.8 | 20.7 | 21.2 | 21.6 | 22.3 | 22.8 | 22.8 | 23.2 | 23.6 |
| | 4H | 19.9 | 20.4 | 20.3 | 20.8 | 21.2 | 21.4 | 22.0 | 21.9 | 22.4 | 22.8 |
| | 6H | 20.4 | 20.8 | 20.9 | 21.3 | 21.7 | 22.1 | 22.5 | 22.6 | 23.0 | 23.4 |
| | 8H | 20.6 | 21.0 | 21.1 | 21.4 | 21.9 | 22.4 | 22.8 | 22.9 | 23.2 | 23.7 |
| 12H | 12H | 20.8 | 21.1 | 21.3 | 21.6 | 22.1 | 22.7 | 23.0 | 23.2 | 23.5 | 24.0 |
| | 4H | 19.9 | 20.4 | 20.4 | 20.8 | 21.2 | 21.4 | 21.9 | 21.9 | 22.3 | 22.7 |
| | 6H | 20.5 | 20.9 | 21.0 | 21.3 | 21.8 | 22.1 | 22.5 | 22.6 | 22.9 | 23.4 |
| 8H | 20.7 | 21.1 | 21.2 | 21.5 | 22.0 | 22.5 | 22.8 | 23.0 | 23.3 | 23.8 | |
| Variation of the observer position for the luminaire distances S | | | | | | | | | | | |
| S = 1.0H | | +0.4 / -0.6 | | | | | +0.5 / -0.5 | | | | |
| S = 1.5H | | +0.8 / -1.1 | | | | | +1.4 / -1.0 | | | | |
| S = 2.0H | | +1.7 / -1.5 | | | | | +2.6 / -1.5 | | | | |
| Standard table | | BK04 | | | | | BK04 | | | | |
| Correction summand | | 1.8 | | | | | 3.6 | | | | |
| Corrected glare indices referring to 1006lm Total luminous flux | | | | | | | | | | | |

The UGR values are calculated in acc. with CIE Publ. 117. Spacing-to-Height-Ratio = 0.25